

MC-20-2021

Request or Bid for Supply of Pipes, fittings, tools and pump maintenance equipment for different JVA water projects in Jordan



Questions & Answers

#	Question	Answer
1	Will Mercy corps reconsider the tender bond amount?	Yes, please refer to "Addendum to tender package document."
2	Whether the delivery time of 45 days is obligatory ?	Yes, the delivery time has been extended by (15) Calneder days to be 60 calendar days instead of 45 calendar days. please refer to "Addendum to tender package" document.
3	is it possible to reduce offer validity to be less than 180 days?	Yes, offer validity has been modified to [120] calendar days instead of [180]. Please refer to "Addendum to tender package" document.
4	what is the country of origins required for the 4 lists?	COO - Country Of Origin for each item is specified in Attachment # 6 - Response sheet.
5	Is partial quoting is acceptable for items?	Only partial submission for item(s)/list(s) is allowed. Partial submission of quantity(s) of the same item is NOT allowed. The supplier can offer the available item(s) at his end.
6	According to Attachment 5- Price Offer Sheet 3 of 4: you mention Item No. 25 as 2 time, so please clear that new item or its mistake ?	This item is no longer exists in this list, please refer to "Addendum to tender package" document.
7	•You mention that we can Submission of Sealed Offers (hard copy) or Soft copy submission , so if we choose Soft copy, then how we can give you Tender Bond ?	Tender bonds must be submitted by hand anytime before the specified deadline.
8	Are we obligated to bid for the whole inquiry? Lot ? Or can we bid per item ?	Only partial submission for item(s)/list(s) is allowed. Partial submission of quantity(s) of the same item is NOT allowed. The supplier can offer the available item(s) at his end.
9	Tender bid bond: Is it a fixed value of 20,000 JODs or 30% of the total tender value ?	The value of the tender bond has been modified to a percentage instead of a fixed value. Bidder to submit a tender bond with 5% of the total value of the quoted items valid for three (3) months. Please refer to "Addendum to tender package" document.
10	Number of tested samples required per item (percentage of items need to be tested)	<u>List No. (1):</u> • One sample from each item is enough. • All samples should be collected by JVA, and JVA should attend for handing in and collecting of samples to/from the third party. (JVA will not accept pre-testing reports). • JVA accept Amman custom laboratory as The third party (instead of RSS) for this list. • All tests should be non-destructive, and all tested samples must be returned back to JVA. <u>List No. (2):</u> • One sample from each item is enough. • All samples should be collected by JVA, and JVA should attend for handing in and collecting of samples to/from the third party. (JVA will not accept pre-testing reports). • JVA Accept RSS as the third party. • The tests should be carried out according to the Jordanian standards. <u>List No. (3):</u> • One sample from each item is enough. • All samples should be collected by JVA, and JVA should attend both, handing in and collecting of samples to and from the third party. (JVA will not accept pre-testing reports). • JVA Accept RSS as the third party. • The tests should be carried out According to the ASTM standards. <u>List No. (4):</u> • For items (1 – 4, and 11-33), it is enough to hand in factory data sheets, tests report, and QC & QA (if applicable) reports, in addition to the certificate of origin. • For items (5-10), One sample from each item will be tested. All
	What are the required tests per item	
	what are the items that needs to be tested	
	Third party inspection (page 5 section 2.1.1.Third Party Witness) double check	
	RSS tests are required for some items and the other Items JVA to determine the name of the third party inspector	
10	If the supplier have items in the stock and they are already tested (certificates are available) should the supplier test them again ?	

MC-20-2021

Request or Bid for Supply of Pipes, fittings, tools and pump maintenance equipment for different JVA water projects in Jordan



Questions & Answers

#	Question	Answer
11	List-4 point # 1 what is cable length for both: Welding Cable 70 mm2 Earth Cable 70 mm2	Welding cable and earth cable length should be 40 meters each.
12	List-3 point # 1,2,5 JVA to determine what is the exact pressure number "PN" 10 or 16	The working pressure is 16 bar
13	List-3 point # 9-12 JVA to determine what is the exact pressure number "PN "	The working pressure is 16 bar
14	List-4 Item 32 and 33 have the same specifications, are they duplicated by mistake? Shall we remove one of them?	One should be dropped.
15	List-4 point # 14 Gel Battery; is it electric (cells) or solar battery?	The Required ones are electric
16	List-4 Points # 15 is the smart charger required is related to point #14 in the same list	the charger <u>shouldn't be smart and is 24 v dc.</u>
17	List-4 point # 28-32 what is the type of Bearing?	all sub-types (C, C3, B, BEA ...etc.) that are of the same bearing NO. should be priced.
12	What are the obligations of the supplier in terms of delivery and handling? Will JVA offer any equipment for handling?	The supplier should deliver all materials to JVA stores in Dier Alla, and JVA will not offer any equipment for handling.
13	Will JVA prepare a specific Area to store the items?	JVA will prepare specific areas for the items.
14	When shall the awarded bidder notify JVA of the delivery occurrence?	The awarded bidders should notify JVA of the delivery occurrence not less than five days before the intended time of delivery.
15	for the DUCTILE IRON items; What is the thickness or schedule or the pipe? for the DUCTILE IRON items pipe end and connection.	<ul style="list-style-type: none"> • <u>Ductile pipes K9</u> • <u>Description:</u> <ul style="list-style-type: none"> - Ductile iron pipes supplied in accordance with standard of ISO2531:1998 .K9 - Effective length is 6 meters. - Class K9 with spigot and socket ends. - The pipes shall be provided with 100% quantity of NBR ring or SBR ring or EPDM ring as per ISO4633. • <u>Specifications:</u> <ul style="list-style-type: none"> - Application: water - Shape: round - Pipe wall thickness: 6mm -11.7mm - Inner cement line: Portland cement line as per ISO4179 - Zinc coating at least 130g/m2 as per ISO8179 - Bitumen painting at least 70 microns as per ISO 8179 - Tensile strength (Mpa): > or equal to 420 - Yield strength (Mpa) : > or equal to 300 - Bending strength (Mpa) : > or equal to 590 - Elongation (%): > or equal to 10 - Brinell hardness (hps): < or equal to 230 - T type mechanical joint